



Unit A1, The Avenues, Eleventh Avenue North,
 Team Valley Trading Estate, Gateshead NE11 0NU
 Tel: 0191 491 0111
 Fax: 0191 482 0111
 Email: service@coolbreeze.co.uk
 Web: www.coolbreeze.co.uk

Report Number
 26580

Vehicle Reg	NO14 GVK	Date	23.1.15	Job Ref		Engineer	TREBOR BELL		
Customer	ESH	Site Name	WYNDHAM HALL	Address	WYNDHAM PARK.				
Contact		Equipment Location	EVERETT CENTRE	Condition of Plant	Good <input type="checkbox"/>	Average <input type="checkbox"/>	Poor <input type="checkbox"/>		
Reason for Visit	Maintenance <input type="checkbox"/>	Repair <input checked="" type="checkbox"/>	Callout <input type="checkbox"/>	Commissioning <input type="checkbox"/>	Warranty <input type="checkbox"/>	Serial No	12423/302605280001	Asset No	
Make	RHOS	Model No	TC AV132026005941	Serial No	12423/302605280001	Asset No		Quotation Required <input type="checkbox"/>	
Refrigerant Type		Circuit A		Kg		Circuit B		Kg	
Health & Safety Checklist		Circuit C		Kg		Works Complete	Yes <input type="checkbox"/>	No <input type="checkbox"/>	
Risk Assessment Completed	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>	Date		Time On Site		Time Off Site	
Permit To Work	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>	Site Hours		O/T Hours		Travel Hours	
Lone Worker	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>	Miles		Expenses			
PPE Equipment	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>						
F-Gas Register Completed	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>						
Refrigerant Used	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>	23.1.15					
Materials Required						Works Carried Out			Materials Used
2 Flow Success						CHARGE NO2, FILLIO INUEE NEW CONDENSOR FAN MOTORS AND CONDENS. POWERED UP TO START			3 FAN MOTORS
2 CRANKCASE HEATERS						CRANKCASE HEATERS BUT FOUND BOTH W/ S. TWO NEW HEATERS REQUESTED FOR COMPRESSOR NO'S SRC-S-133-444 SN'R00075360. BOTH ARE 240V. PHOTO TAKEN. REMOVED AS MUCH LEAF LITTER AND RUBBERY FROM CURTAIN COMPART. CLEANED CONDENSOR COILS AND WASH IN GENERAL. AWASHED WATER TREATMENT BEFORE CHARGES CAN BE TESTED.			
Further Works Required						Refrigerant Cylinders			
						New			
						Recovery			
						Recycle			
						Waste Transfer	Yes <input type="checkbox"/>	No <input type="checkbox"/>	
						Cylinder No			
						Cylinder No			
Customer Remarks						Engineer Signature			
Customer Name & Signature									

YVONNE NAISBITT, [Signature]